

RIDGEWAY

Ridgeway
103 Airport Road West
Belfast
BT3 9ED
T: 02890 454599
info@ridgeway-online.com
www.ridgeway-online.com

Product Description

4.55mm Hesco Concertainer Inserted Bastion

Spec. No. 455HCIB Issue 1

01.05.05

Manufacture

Inserted Concertainer Bastions shall be manufactured from a hard drawn steel wire formed into a bi-axial mesh grid by electrically welding the cross wires at every intersection.

Inserted Concertainer bastions: to be factory assembled with helicals on vertical joints, and pre cut and folded non- woven geotextile liner permanently fixed to inner faces.

Additional internal diaphragms to the face of the bastion shall be provided to facilitate stone filling. Additional transverse mesh diaphragms shall be provided to facilitate stone filling and act as drainage paths.

Mesh Size

Mesh opening shall be square of nominal dimension of 75mm on the grid.

Wire Diameter

Nominal wire diameter shall be 4.55mm to BS 1052.

Corrosion Protection

Wire shall be Bezinal coated (95% Zinc 5% Aluminium) having an average minimum coating weight of 350g/sq m.

Durability

60 years life expectancy in a mild environment provided the geotextile liner is totally obscured from direct sunlight.

Jointing

Bastions shall be provided with locking pins for assembly and with lacing wire of nominal wire diameter 2.5mm (all in accordance with the corrosion specified) for final jointing.

Bastion fill

Bastion fill shall be a compactable granular material, deposited into the mid third of the unit before evenly spreading across the Bastion, in layers not exceeding 300mm. The fill to be well compacted before subsequent layers are added.

Health & Safety

All joints on the face of the structure are to be snagged to ensure no cut ends of mesh or wire is exposed to cause injury or damage to clothing.